



---

### Mechanical Refrigeration FAQs

**1. What are the Safety and Professional Services rules governing the installation of mechanical refrigeration equipment?**

**A:** Safety and Professional Services' administrative rules for refrigeration are found in SPS 345. The rules are enforced by Division of Industry Services inspectors and the Department's authorized agents.

**2. What type of refrigeration systems require inspection and how is Division of Industry Services providing notification of refrigeration systems requiring inspection?**

**A:** Per [SPS 345.30](#), systems using an A1 or B1 refrigerant and having a capacity rated at or greater than 50 horsepower, 50 tons or 50,000 volt-amperes and A2/B2 and A3/B3 refrigerants having a capacity rated at or greater than 10 horsepower, 10 tons or 10,000 voltamperes are required to be registered and inspected. A contractor must submit the [SBD-34](#) refrigeration registration form prior to installation of the system.